

**SANITARY CERTIFICATE**

Certified that **ZION INTERNATIONAL SCHOOL, 24 MM Street, Kodaikanal**, has been inspected on 27.05.2022 and premises are found satisfactory on the following aspect.


1. The rooms and surroundings are maintained neat clean.
2. The Sanitary arrangements provided are adequate and satisfactory.

**This Certificate is issued subject to the following the conditions:**

1. The Garbage generated within the home be collected and disposed of properly by appointing sanitary staff.
2. On any account the Garbage should not be burnt
3. The Children should be educated to prevent the usage of Plastic in the home premises and no one should bring plastic carry bags, use and throw Tumblers to the home.
4. Fire precaution measures and first aid box should be provided.
5. This Certificate issued is liable to be cancelled at any time on infringement if any of the above said conditions and for improper maintenance of buildings as well as toilet in the home and **valid for one year only from the date of issue.**
6. Child Labour should not be engaged on any account.
7. **Display and Exhibition of Board**

As per rule 3 of the Tamil Nadu Prohibition and smoking and spitting rules 2003.

- a) Every person in charge of place of Public work or use shall display and exhibit a board at a conspicuous place in or outside the prominently stating that the Place is a **"No Smoking and No Spitting Place" and the Smoking or Spitting Offence** which shall be both in Tamil and English version.
  - b) The Tamil version shall be written predominately in the board by providing more space than English.
  - c) The size of the Board shall not be less than 1x3 feet.
8. There should not be any Mosquito breeding sources in your home premises.
  9. Purified drinking water should be given to home children's.
  10. Over head tank should be clean regularly with bleaching powder

  
Sanitary Inspector,  
Kodaikanal Municipality.

/Counter signed/

  
Municipal Health officer,  
Kodaikanal Municipality.





# TAMILNADU WATER SUPPLY AND DRAINAGE BOARD

## District Level Water Testing Laboratory

TWAD Board, 5/860 Anbu Illam, NGO Colony,  
Dindigul - 624 005.

### TEST REPORT

Ph. : 0451 - 2410188

**From**

*Er. S. Pitchaiandi, M.E.,*  
Assistant Executive Engineer,  
District Water Testing Lab/RWS Sub Division,  
Dindigul

**To**

*Zion International School,*  
Post Box. No.24,  
MM Street, Kodaikanal  
Dindigul (Dt),

Lr No.835 & B836 /AEE/Dist Lab/Dgl/2019/dt/10.19.

Sub: Examination of Water sample- report -furnished - reg.

Ref : Chief Water Analyst, Lr No : 58-1/CWA/TWAD/2018/dt 24.10.2018

The result of analysis for the samples sent under reference is enclosed.

Source: RO

Location : MM Street, Kodaikanal

Date of Collection : 15.10.19.

Date of Receipt : 15.10.19.

I. PHYSICAL EXAMINATION:	BIS Limit: (10500: 2012)		Lab No
	Acceptable limit	Permissible limit in the absence of alternative source	835
1. Appearance	-	-	Clear & Colourless
2. Colour (pt.co-scale)	5	15	
3. Odour	Unobjectionable		
4. Turbidity NT Units	1	5	None
5. Total dissolved Solids mg/l	500	2000	0
6. Electrical Conductivity Micro mho/cm	-	-	501
<b>II. CHEMICAL EXAMINATION:</b>			
7. pH	6.5-8.5	6.5-8.5	910
8. Ph. Alkalinity as CaCO <sub>3</sub>	-	-	6.5
9. Total Alk. as CaCO <sub>3</sub>	200	600	0
10. Total Hardness as CaCO <sub>3</sub>	200	600	32
11. Calcium as Ca	75	200	276
12. Magnesium as Mg	30	100	0
13. Iron as Fe	0.1	1.0	0
14. Manganese	0.1	0.3	0
15. Free Ammonia as NH <sub>3</sub>	0.5	0.5	0
16. Nitrite as NO <sub>2</sub>	0.5	0.5	0
17. Nitrate as NO <sub>3</sub>	45	45	0
18. Chloride as Cl	250	1000	110
19. Fluoride as F	1.0	1.5	0.0
20. Sulphate as SO <sub>4</sub>	200	400	0
21. Phosphate as PO <sub>4</sub>	0.5	0.5	0
22. Tidy's Test 4 hrs. as O <sub>2</sub>	-	-	0.0
23. Residual Chlorine as RC	0.2	0.5	0.0
<b>III. BACTERIOLOGICAL EXAMINATION:</b>			
24. Faecal coliform per 100 ml	0	0/100 ml	B836
			0

**Result:** The given water sample is chemically potable. And Bacteriologically not contaminated.